



CONCENTRIC VENT KIT

This accessory allows both the intake for combustion air and the exhaust vent to pass through a common roof or sidewall penetration. This termination is available as an option to the standard two pipe intake/vent.

This kit contains the following parts:

- (1) PVC Combustion Air inlet Cap
- (1) PVC Air Inlet Pipe
- (1) PVC Vent Pipe
- (1) PVC Intake Vent Concentric "Y"

VENTI PART NO.	INTAKE AND VENT NOM PIPE DIA	ASSEMBLED LENGTH	INLET PIPE LENGTH	INTAKE PIPE (OD)
P4D02VK	2"	34 3/4"	27 1/4"	3 1/2"
P4D03VK	3"	39 3/4"	31 7/8"	4 1/2"

Installation

Field supplied pipe and fittings are required to complete the installation. The combustion air and vent pipe fittings must conform to American National Standards Institute (ANSI) and American Society for Testing and Materials (ASTM) standards D1785 (schedule-40 PVC), D2665 (PVC-DWV), D2441 (SDR-21 and SDR 26 PVC), D2661 (ABS DWV), or F628 (schedule-40 ABS). Pipe cement and primer must conform to ASTM standards D2564 (PVC) or D2235 (ABS). In Canada, construct all combustion air inlet and exhaust vent pipes for this unit with CSA or ULC certified Schedule-40 PVC, PVC-DWV pipe and pipe cement.

WARNING:
 For use with condensing gas furnace models. Vent Kit must be used only for terminating the vent of a Category IV furnace. Do not use this termination kit for any other type furnace. This installation shall be done by a qualified service agency in accordance with these instructions, all applicable codes, and requirements of the authority having jurisdiction. Failure to follow these instructions could result in substantial property damage, severe personal injury, or death.

 Prop 65 Warning:
 This product contains a chemical known to the State of California to cause cancer.

